



Town of Gates

Fire Marshal's Office

jmcnulty@townofgates.org

1605 Buffalo Road
Rochester, New York 14624
Office (585) 247-6100
Fax (585) 426-8581

RECALL ALERT!

Kidde has recalled certain Smoke and Combination Smoke/Carbon Monoxide Alarms for failure to alert!

These devices were sold between MAY 2019 and SEPTEMBER 2020. Verify if you have one of these devices based on the model numbers listed below. **If you have one of the affected devices please contact Kidde at the consumer contact information listed below for a replacement detector from Kidde.**

Consumer Contact:

Kidde toll-free at 844-796-9972 from 8 a.m. to 8 p.m. ET Monday through Friday and 9 a.m. to 3 p.m. ET on Saturday or online at www.kiddetsalarmrecall.rsvpcomm.com or www.kidde.com and click on "Support" and then "Product Alerts" for more information.

Description:

This recall involves Kidde TruSense Smoke Alarms and Combination Smoke/Carbon Monoxide Alarms. The recalled units are Kidde Model Series 2040, 2050, 2060 and 2070 Smoke and Combination Smoke/Carbon Monoxide alarms. Only alarms with the TruSense logo or "AMBER=FAULT" printed on the front of the alarm are included in this recall. The model number is printed on the back of the alarm.

Model	Alarm Type
2040-DSR	Smoke
2050-DS10	Smoke
2060-ASR	Smoke
2070-VDSCR	Combination Smoke/Carbon Monoxide
2070-VASCR	Combination Smoke/Carbon Monoxide
2070-VDSR	Smoke
2070-VASR	Smoke

Remedy:

Consumers should immediately contact Kidde for a free replacement alarm. Consumers should keep using the recalled alarms until they install replacement alarms.

Incidents/Injuries:

No incidents or injuries have been reported.

Sold At:

Walmart, Home Depot, Menards and other department, home and hardware stores and electrical distributors nationwide, and online at Amazon.com, ShopKidde.com and other online retailers from May 2019 through September 2020 for between \$10 and \$70.

Importer(s):

Walter Kidde Portable Equipment Company Inc., of Mebane, N.C.

Manufactured In:

China

Recall number:

21-130

If you are a resident of the Gates Fire District and need a smoke and/or carbon monoxide detector, please call the Gates Fire District at 585-426-2720 to schedule an appointment.